

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**

**LISTING No.** 3550-0610:115 Page 1 of 1

**CATEGORY:** Door Closers/Holders

**LISTEE:** Dorma Door Controls, Dorma Drive, Reamstown, PA 17567-0411  
Contact: Rick Loose (717) 336-3881

**DESIGN:** Model ED 800 door operator with automatic closer. Refer to listee's data sheet for detailed description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product designation, electrical rating and UL label.

**APPROVAL:** Listed as a door closer intended to be connected to doors from 36" wide and 100 pounds to 48" wide to 200 pounds. Intended to be conduit connected 120V.



---

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**  
**Program Manager**